

**Cold compressor and buffer/subcooler Dewar
for superconducting solenoid
Helium supply and return lines.**

D-ZERO ENGINEERING NOTE # 3823.115-EN-574

January 25, 2005

Author: Michael Sarychev


Engineer

PPD/MSD/D0 Operations

Dzero experiment needs to drop the operating temperature of the superconducting solenoid. In order to do this, a cold compressor (vessel # RSB416), along with a two-phase return Dewar (vessel # RSB409) will be installed in Dzero Assembly building in the Helium refrigerator area (flow diagram attached). The cold compressor will be installed on a 2-phase Helium return line from the solenoid and its purpose will be to drop the return line and existing LHe subcooler (located in the solenoid Control Dewar) pressure, and therefore decrease the solenoid operating temperature. The low pressure side of the buffer/subcooler Dewar will serve as a buffer volume for the cold compressor and will be connected to the same return line. The high pressure side of this Dewar (the coil) will be used to subcool LHe supply to the solenoid. Those vessels were previously used in Tevatron satellite refrigerator buildings. Relieving devices settings and sizing were reviewed, and it has been determined that they are not system dependent and apply to the corresponding vessels only; they are deemed appropriate and will be kept unchanged in new system configuration. The original instrumentation will not be changed as well. Therefore, since there is no subsequent changes in contents, pressures, temperatures, valving, etc., affecting the safety of those vessels, no additional review of original pressure vessel engineering notes (vessels RSB409 and RSB416) is required (per Fermilab ES&H Manual Chapter 5031).

Attachments:

1. Original Pressure Vessel Engineering notes for RSB409 and RSB416
2. Cold compressor and subcooler/buffer connections flow diagram



OK
H. Caselott

Prepared by: J.D. Fuerst

Preparation date: 7/29/88

1. Description and Identification

Fill in the label information below:

This vessel conforms to engineering standard SD37
Vessel Title 2- Phase Return Dewar
Vessel Number RSB409
Vessel Drawing Number 1650-ME-168945
Maximum Allowable
Working Pressure (MAWP) 100 PSI
Working Temperature Range -450 °F 100 °F
Contents Helium
Designer/Manufacturer T.J. Peterson - J.D. Fuerst/
Fermilab
Test Pressure (if tested at Fermi) Acceptance
Date: 8/11/88
125 PSI, Hydraulic Pneumatic ☒
Accepted as conforming to standard by
H. Caselott
of Division/Section FCC Div 10/13/88
NOTE: Any subsequent changes in contents, pressures,
temperatures, valving, etc., which affect the safety of
this vessel shall require another review and test.

Obtain from
☒ Division/Section
Safety Officer

Actual signature
☒ required in this
space

Reviewed by: *KG Weber* Date: 8/9/88

Director's signature (or designee) if the vessel is for manned areas but doesn't
conform to the requirements of the standard.

Date: _____

Lab Property Number(s): _____

Lab Location Code: _____

Purpose of Vessel(s): Provide buffer volume and aftercooling for proposed
cold compressor installation in satellite refrigerator buildings.

Vessel Capacity/Size: 100 liter Diameter: 24" Length: 50"

Normal Operating Pressure (OP) 3 PSIG

MAWP-OP = 97 PSI

Is the above enough to provide relief cracking pressure tolerance plus system
uncertainty tolerance per M-9.

As an option, provide a photo of the entire vessel in the Appendix.


List the number of all pertinent drawings and the location of the originals.
(Appended copies).

<u>Drawing #</u>	<u>Location of Original</u>
<u>1650-ME-168945</u>	<u>East Booster Tower</u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>

- 2 Design Verification
Does the vessel(s) have a U stamp? Yes No X. If "Yes", fill out data below and skip page 3; if "No", fill out page 3 and skip this page.


Staple photo of U stamp plate below.

Copy "U" label details to the side if photo is not clear or if copies are unreadable.



Copy data here:

On the sketch below, circle all applicable sections of the ASME code per Section VIII, Division I. list the results of all calculations. (Insert copies of calculations in the appendix).



Summary of ASME Code

Item	Reference ASME Code Section	CALCULATION RESULT (Required thickness or stress level vs. actual thickness or calculated stress level)
See Appendix	for calculations	vs.
Heads (Inner &	outer vessel)	vs.
Shells (Inner	& outer vessel)	vs.
		vs.
		vs.

If this vessel is exceptional or had exceptional parts, list their details under 5.6. Yes _____ No X

- 3 System Venting. Provide the system schematic in the Appendix, if the vessel safety is system sensitive.

Is it possible to isolate the relief valves by a valve from the vessel?

Yes _____ No X _____

If "Yes", the system must conform to M-5. Provide an explanation of the appended schematic. (An isolatable vessel, not conforming to M-5 violates the Standard.)

Is the relief cracking pressure set at or below the M.A.W.P.?

Yes X No _____ Actual setting 65 PSIG
(A no response violates the Standard.)

Is the pressure drop of the relief system at maximum anticipated flow such that vessel pressure never rises above the following? (UG 125)

Yes X No _____
110% of MAWP (one relief)
116% of MAWP (multiple reliefs)
121% of MAWP (unexpected heat source)

Provide test or calculational proof in the Appendix.
(Non-conforming pressure rises violate the Standard.)

List of reliefs and settings:

<u>Manufacturer</u>	<u>Relief</u>	<u>Setting</u>	<u>Flow Rate</u>	<u>Size</u>
<u>Circle Seal</u>	<u>Valve</u>	<u>65 psig</u>	<u>425 scfm air</u>	<u>1"</u>
<u>#M5120-N-8M-65ASME</u>	_____	_____	_____	_____
<u>Continental</u>	<u>Disc</u>	<u>93 psig</u>	<u>2400 scfm air</u>	<u>1"</u>
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Is the relief device an ASME stamped device? Yes X No _____

4 Operating Procedure

Is an operating procedure necessary for the safe operation of this vessel?

Yes X No _____. If "Yes", please append.

5. Welding Information

Has the vessel been fabricated in a Fermilab shop? Yes X No _____

If "Yes", append a copy of the welding shop statement of welder qualification and a copy of the Welding Procedure Specification (WPS) used to weld this vessel.

6 Exceptional, Existing, Used, and Non-Manned Area Vessels

Is this vessel or any part thereof in the above categories? Yes _____ No X _____


If "Yes", follow the Engineering Note requirements for documentation in free form below.

Procedure for Putting the
2-Phase Return Dewar On-line at A1

Tom Peterson TJP
May 11, 1987

1. PUMP AND BACKFILL tube side (HP) and dewar (LP) with helium at least 5 times. Leave about 10 psig helium in both. (~~Dewar relief cracks at about 10 psig~~) JPF
2. CRASH BUILDING (close EV-101)
3. EVBY Local Open.
4. EVLH Local Close.
5. EVJT Local Open.
6. Engines off, pressures all ≤ 10 psig.
7. PULL long HP U-tube.
8. PURGE and INSERT valvebox to dewar HP U-tube.
9. PURGE and INSERT heat exchanger end box to dewar HP U-tube.
10. PULL long LP U-tube.
11. PURGE and INSERT valvebox to dewar LP U-TUBE.
12. PURGE and INSERT heat exchanger end box to dewar LP U-tube.
13. EVJT CLOSE (still local).
14. OPEN EV-101.
15. EVLH OPEN (still local).
16. RUN WET ENGINE SLOWLY
bypass still open so cooling 2-phase return dewar.
Watch wet engine and dewar VPT's for cooling.
17. When dewar and wet engine cold enough (a judgement call) put EVJT, EVBY, EVLH, WET ENGINE in REMOTE.

es



Appendix
Revised 9-SEP-88

Outline of Code Calculations

- I. STAINLESS STEEL INNER VESSEL
 - A. Internal Pressure
 - 1. Heads
 - 2. Shell
 - 3. Head/Neck weld reinforcement
 - B. External Pressure
 - 1. Heads
 - 2. Shell
- II. STAINLESS STEEL VACUUM VESSEL
 - A. Internal Pressure
 - 1. Heads
 - 2. Shell
 - 3. Head/Neck Weld reinforcement
 - B. External Pressure
 - 1. Heads
 - 2. Shell
- III. RELIEF VALVE SIZING
 - A. Vacuum Vessel
 - B. Inner Vessel
 - 1. Failure Modes
 - 2. Relief Capacities
- IV. SUMMARY OF CALCULATIONS

I. STAINLESS STEEL INNER VESSEL

This vessel was constructed by the Accelerator Division Cryogenic Systems Group at Fermilab. Since it is not clear whether 304 or 304L stainless steel was used in fabrication, calculations are performed assuming 304L.

A. Internal Pressure

1. Heads UG-32 (ellipsoidal)

$$\begin{aligned}P &= 2SEt/(D+0.2t) \\S &= \text{max. all stress value, psi} = (13300)(.85)(.80) = 9044 \\E &= \text{joint efficiency (weld)} = 1.0 \text{ (no welds in head)} \\t &= \text{thickness in} = 0.25 \\D &= \text{inside length of maj. axis of head} = 18''\end{aligned}$$

$$P = \underline{250 \text{ psi}}$$

2. Shell UG - 27 (welded pipe)

$$\begin{aligned}S &= (13300)(.80) = 10640 \text{ psi} \\E &= 0.6 \text{ (UW-12)} \\R &= \text{inside radius of shell, in.} = 8.75 \\P &= SEt/(R+0.6t)(\text{circumferential}) = 179 \text{ psi} \\P &= 2SEt/(R-0.4t)(\text{longitudinal}) = 369 \text{ psi}\end{aligned}$$

$$P = \underline{179 \text{ psi}}$$

3. Head/Neck Weld Reinforcement UG-37

$$\begin{aligned}d &= \text{opening dia.} = 1.90 - 2(0.109) = 1.682'' \\F &= \text{corr. factor for plane angle} = 1 \\P &= \text{MAWP} = 115 \text{ psia} \\E &= 1 \\D &= 18'' \\t_r &= \text{req'd thickness} = PD/(2SE - 0.2P) = 0.1146'' \\A &= A_{\text{req'd}} = dt_r F = (1.682)(0.1146)(1) = 0.1928 \text{ ins}^2 \\A_{\text{act}} &= d(t-t_r)F = (1.682)(0.1354)(1) = 0.2277 \text{ in}^2 \\A_{\text{act}} &> A \text{ (req'd) therefore } \underline{\text{no additional reinforcement req'd.}}\end{aligned}$$

B. External Pressure

1. Heads UG - 33

$$P_1 = P_{\text{concave}}/(1.67) \text{ or } P_2 = B/(R_o/t), \text{ whichever is less.}$$

$$P_{\text{concave}} = 250 \text{ psi} \therefore P_1 = 150 \text{ psi}$$

"A" = $0.125/(R_o/t)$ where R_o = equiv. outside spherical radius, in. Using table UG-33.1, $R_o = 16.2$.

$$t = \text{head thickness, in.} = 0.25$$

$$A = 0.0019 \text{ therefore "B" } = 10000 \\ (\text{fig. 5-UHA-28.3 up to } 100\text{F})$$

$$P_2 = 154 \text{ psi so } P_1 < P_2$$

$$P = \underline{150 \text{ psi}}$$

2. Shell UG - 28C

$$L = \text{shell length, in.} = 20" \text{ (incl. head skirts)}$$

$$D_o = \text{outside dia. of shell, in.} = 18"$$

$$t = 0.25"$$

$$\text{then } D_o/t = 80 (> 10) \text{ and } L/D_o = 1.111$$

$$\therefore \text{factor "A" } = 0.0018 \text{ and "B" } = 10000 \text{ (fig. 5-UHA-28.3 up to } 100\text{F)}$$

$$P = 4B/3(D_o/t)$$

$$P = \underline{167 \text{ psi}}$$

II. STAINLESS STEEL VACUUM VESSEL

This vessel was constructed by the Accelerator Division Cryogenic Systems Group at Fermilab. Since it is not clear whether 304 or 304L stainless steel was used in fabrication, calculations are performed assuming 304L.

A. Internal Pressure

1. Heads UG - 32 (as per inner vessel) $t = 0.25$ in.
 $D = 24$ in.

$$P = \underline{188 \text{ psi}}$$

2. Shell UG - 27 (as per inner vessel) $R = 12$ in.

$$\begin{array}{ll} \text{Circumferential:} & P = 131 \text{ psi} \\ \text{Longitudinal :} & P = 268 \text{ psi} \end{array}$$

$$P = \underline{131 \text{ psi}}$$

3. Head/Neck Weld reinforcement UG - 37
(as per inner vessel)

$$d = 3.5'' - 2(0.083'') = 3.334'' \text{ (worst case)}$$

$$D = 24''$$

$$P = 1.67 \text{ (required ext. press. per SD-41)} = 1.67 (7.5 \text{ psia}) = 12.5 \text{ psi}$$

$$E = 1$$

$$F = 1$$

$$t_r = 0.0166''$$

$$A_{\text{req}} = dt_r F = 0.0553 \text{ in}^2$$

$$A_{\text{act}} = d(t - t_r) = 0.7782 \text{ in}^2$$

$$A_{\text{act}} > A_{\text{req'd.}} \text{ therefore } \underline{\text{no additional reinforcement req'd.}}$$

B. External Pressure

1. Heads UG - 33 (as per inner vessel)

$$P_1 = P_{\text{concave}} / (1.67) = 93 \text{ psi}$$

$$''A'' = 0.0014 \text{ where } R_o = 21.6 \text{ and } t = 0.25''$$

therefore $''B'' = 9500 \text{ (fig. 5 UHA-28.3 up to 100 F)}$

so $P_2 = 131 \text{ psi}$

$$P = \underline{93 \text{ psi}}$$

2. Shell UG - 28C

$$L = 32" \text{ (incl. head skirts)}$$

$$D_o = 24"$$

$$t = 0.25"$$

$$D_o/t = 96 (> 10), L/D_o = 1.333$$

$$\text{factor "A"} = .0012, \text{ factor "B"} = 9000 \text{ (as above)}$$

$$\text{then } P = 4B/3(D_o/t)$$

$$P = \underline{125 \text{ psi}}$$

III. RELIEF VALVE SIZING

A. Vacuum Vessel

CGA 341 specifies a minimum 0.00024 in^2 discharge area per pound water capacity of the liquid container.

$$100 \text{ liter inner vessel} = 100 \text{ kg H}_2\text{O} = 220 \text{ lb H}_2\text{O}$$

$$\text{Relief area req'd.} = (0.00024)(220) = 0.0528 \text{ in}^2$$

Actual vacuum relief is a 2" parallel plate device (Fermi dwg. 9130-MC-129784) supplying 3.14 in^2 area.

$$\underline{3.14 \text{ in}^2 \text{ vs. } 0.0528 \text{ in}^2}$$

B. Inner Vessel

$$\text{MAWP} = 100 \text{ psi}$$

1. Failure modes

- a. Loss of vacuum - vacuum filled with 1 atm GHe (vacuum relief point).

$$Q_a = (130-t)/4(1200-t) = G_i U A$$

- b. Loss of vacuum, condensative heat transfer by air - NBS Monograph 111 chart 6.3

- c. Fire condition $Q_a = G_i U A^{0.82}$ from CGA S-1.3

- d. Rupture of finned tubing exposing inner vessel to high pressure.

- Q_a = flow capacity req'd. (SCFM air)
 G_i = 52.5 for He relieving at or below 200 psi (CGA - S-1.3)
 A = outside surface area of vessel (16 ft^2)
 U = total thermal conductance of insulating material ($\text{Btu/hr ft}^2\text{F}$)
when saturated with gaseous lading or air at 1 atm, whichever is greater.
 t = Temp. ($^{\circ}\text{F}$) of gas at pressure and flowing conditions.

Case A:

$$\begin{aligned}
 Q_a &= 130 - t/4(1200 - t) = G_i U A \\
 U &= K/L \text{ where } K = \text{avg. therm. cond. of He (0-300K)} \\
 &= 1.55 \text{ MW/cmK} \\
 L &= \text{thickness of superinsulation} \\
 &= 1" (\sim 60 \text{ layers}) \\
 U &= (1.55 \text{ MW/cmK}) / 2.54 \text{ cm} = 0.6102 \text{ MW/cm}^2\text{K} \\
 &= 1.075 \text{ Btu/hr ft}^2\text{F} \\
 t &= -450^{\circ}\text{F} \\
 \text{so } Q_a &= \{(130 + 450) / [4(1200 + 450)]\} = G_i U A
 \end{aligned}$$

77.4 SCFM air

Case B:

Relieving pressure = $(1.16)(100 + 14.5) = 132.8 \text{ psia}$ from NBS Mono 111 fig. 6A-2 and taking worst case:

$$L' = 14 \text{ Btu/lb efflux}$$

$$T = 10^{\circ}\text{R}$$

From NBS Mono 111 fig. 6.3:

Heat flux = 16000 Btu/hr.

$$16000 \text{ Btu/hr} / (14 \text{ Btu/lb efflux}) = 1143 \text{ lb/hr}$$

$$Q_a = [13.1WC_a/60C][ZTM_a/MZaTa]^{1/2} \text{ from NBS Mono 111 eq. 6A-1}$$

Q_a = req'd capacity, SCFM air

where

W = lb/hr req'd gas flow

C_a = gas const. = 356 for air

C = gas const. of the gas

Z_a = compressibility factor = 1.0 for air @ STP

Z = compressibility factor for the gas @ flow cond.

M_a = molecular weight of air = 28.97

M = molecular weight of the gas

T_a = temp. of air @ STP = 520R

T = temp. of gas @ flow cond.

$$Q_a = \frac{(13.1)(1143)(356)}{60(378)} \left[\frac{0.98(10)(28.97)}{4(1.0)(620)} \right]^{1/2} = 82.3 \text{ SCFM air}$$

Note: It is possible to arrive at higher values of Q_a if different values for L' and T are taken from Fig. 6A-2 of NBS mono 111. For instance, at $L' = 12$ and $T = 12^\circ\text{R}$ along the 100 psia line, $Q_a = 105$ SCFM air. if $L' = 14$ and $T = 14$, then $Q_a = 97.3$ SCFM air. The required relief capacity is the largest of these values.

105 SCFM air

Case C:

$$Q_a = G_i UA^{0.82}$$

$$Q_a = 52.5 (1.075)(16)^{.82} = 548 \text{ SCFM air}$$

548 SCFM air

Case D:

Assume a worst case scenario in which a finned tube becomes disconnected, providing a 1/2" hole from high pressure (up to 300 psi) to vessel pressure (rupture disc burst pressure = 100 psi).

Since under sonic conditions (present here) mass flow scales linearly with both pressure and flow area, one can argue that the required burst disc area must be greater than they envisioned flow area produced by the failure by the ratio of the driving pressures.

- 1/2" hole provides 0.1963 in² of flow area with a back pressure of 300 psi.
- burst disc pressure is 100 psi.
- burst disc area should be:

$$(300/100)(0.1963 \text{ in}^2) = 0.5890 \text{ in}^2$$

This translates to a disc diameter of 0.8660 in.; therefore a 1" disc is considered adequate.

Such a disc will provide 2400 scfm air flow under burst conditions.

2. Relief Capacities

The inner vessel is relieved by one 1" Circle Seal relief valve #5120B-8MP-65 (65 psi relief point). This device is stamped at 425 SCFM. A 1" rupture disc (100 psi burst press.) is also present, supplying 2400 scfm air relieving capacity to satisfy fire conditions and possible rupture of high pressure finned tubing inside vessel.

IV. SUMMARY OF CALCULATIONS

INNER VESSEL

<u>PART</u>	<u>EXTERNAL PRESS</u>		<u>INTERNAL PRESS</u>	
	<u>Actual</u>	<u>Required</u>	<u>Actual</u>	<u>Required</u>
S.S. Heads	150 psi	vs. 7.5 psi	250 psi	vs. 100 psi
S.S. Shell	167 psi	vs. 7.5 psi	179 psi	vs. 100 psi

Relieving capacity: $425 + 2400 = 2825$ SCFM supplied vs. 548 SCFM req'd. (air)

Head/Neck weld reinforcement: 0.2277 in^2 supplied vs. 0.1928 in^2 req'd.

VACUUM VESSEL

<u>PART</u>	<u>EXTERNAL PRESS</u>		<u>INTERNAL PRESS</u>	
	<u>Actual</u>	<u>Required</u>	<u>Actual</u>	<u>Required</u>
Heads	93 psi	7.5 psi	188 psi	< 100 psi
Shell	125 psi	7.5 psi	131 psi	< 100 psi

Relieving capacity: 3.14 in^2 supplied vs. 0.0528 in^2 req'd.

Head/neck weld reinforcement: 0.7782 in^2 supplied vs. 0.0553 in^2 req'd.

jp



PITTSBURGH TESTING LABORATORY

4412 WEST ROOSEVELT ROAD
HILLSDALE, ILLINOIS 60162

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS
ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION
FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING
OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

11-4-76
Lab 1423-61

DESCRIPTION:

Welder Qualification Tests

REPORTED TO:

Fermi National Accelerator Lab
Batavia, Illinois 60510

PROCEDURE QUALIFICATION NO.: FNI-WP 900 SPECIFICATION NO.: FNI-WP 900
WELDER'S NAME: Clint Vickers S.S. NO.: 321-44-1502
SAMPLE NO.: TS-1076-28 POSITION: 6G JOINT TYPE: Vee Groove
DIAMETER: 6" SCHEDULE: 40 QUAL. RANGE: 0.062 to 0.560

RADIOGRAPHIC RESULTS:

GUIDED BEND TEST RESULTS: Face #1 Passed Root #2 Passed
Face #3 Passed Root #4 Passed

REDUCED SECTION TENSILE TESTS:


SPECIMEN NO.	DIMENSIONS - INCHES		AREA SQ. IN.	ULTIMATE TOTAL LOAD, LBS.	ULTIMATE UNIT STRESS, PSI	CHARACTER OF FAILURE AND LOCATION
	WIDTH	THICKNESS				

RESULTS (DO/EXCER) MEET REQUIREMENTS OF ASME SECTION IX AND III

TESTING CONDUCTED BY: PITTSBURGH TESTING LABORATORY


DAVID A. DUNN, DISTRICT MANAGER

TESTING WITNESSED BY: NUCLEAR WELDING, INC.


JOHN H. ROBERTSON

ADDENDUM

J.D. Fuerst 8/10/88

Temporary Primary Relief Valve Installed on the Second 2-Phase Dewar

The design for the 2-phase return dewar calls for one 1" 65 psi ASME coded Circle Seal relief (#M5120-N-8M-65ASME) as primary relief and one 1" 100 psi rupture disc as secondary (required only by the fire condition).

As of this writing, the Cryogenic Systems group has not received the 65 psi Circle Seal relief from the vendor; it is expected at the beginning of September. Consequently, we are forced to use an appropriate alternative if we wish to begin testing before the Circle Seal arrives.

We located an Anderson Greenwood type 81S relief valve with a 1/2" orifice set for 145 psi. After ordering the proper spring for resetting, the valve was reconfigured by qualified, AGCO certified Fermilab personnel to relieve at 65 psig. The valve was tested to verify this relief setting. According to the Anderson Greenwood catalog, this valve will pass 252 SCFM with a 65 psig relief point.

252 SCFM is sufficient for all relief conditions except for the fire condition (the Circle Seal by itself is also insufficient for fire conditions). In that case, the rupture disc will blow and provide more than enough relieving capacity.

After the Circle Seal relief arrives, we will wait for an opportunity to warm up the vessel. We will then replace the temporary A&G relief with the Circle Seal. Since the A&G is a temporary relief, it was not considered necessary to rewrite this 2-phase return dewar's engineering note to reflect the change. This addendum has been written to clarify this issue.

Preparer's signature

J.D. Fuerst 8/10/88

Reviewer's signature

Katharine J. Weber 8/11/88

1111111111

10/14/88

**Accelerator Division
Cryogenic Systems Group**

Welder Qualification Voucher

The vessel Two-Phase Return Dewar RSB409,
has been welded in accordance with Fermilab drawing
#1650-MD-257650, "Accelerator Cryogenic Systems -
Cryogenic Pressure Vessels - Typical Welded Joint
Designs" and in agreement with generally accepted welding
practice.

The welders involved with the fabrication of this vessel
(listed below) are qualified to perform the aforementioned
welds, as attested to by the completion of Welder
Qualification Tests and in the judgement of the Lead
Welder.

Welders

J. O'Neill

M. Santana

R. Krause


R. Williams

Lead Welder

James M. O'Neill

Date

10/14/88




SAMPLE WELDED JOINT LOCATIONS TYPICAL OF CATEGORIES A,B,C & D

CATEGORY A - LONGITUDINAL WELDED JOINTS WITHIN THE MAIN SHELL, COMMUNICATING CHAMBERS, TRANSITIONS IN DIAMETER, OR NOZZLES; ANY WELDED JOINT WITHIN A FORMED OR FLAT HEAD, OF THE SIDE PLATES OF A PLAT SIDED VESSEL.

CATEGORY B - CIRCUMFERENTIAL WELDED JOINTS WITHIN THE MAIN SHELL, COMMUNICATING CHAMBERS, NOZZLES, OR TRANSITIONS IN DIAMETER INCLUDING JOINTS BETWEEN THE TRANSITION AND A CYLINDER AT EITHER THE LARGE OR SMALL END; CIRCUMFERENTIAL WELDED JOINTS CONNECTING FORMED HEADS OTHER THAN HEMISPHERICAL TO MAIN SHELLS, TO TRANSITIONS IN DIAMETER, TO NOZZLES, OR TO COMMUNICATING CHAMBERS.


CATEGORY C - WELDED JOINTS CONNECTING FLANGES OR PLAT HEADS TO MAIN SHELL, TO FORMED HEADS, TO TRANSITIONS IN DIAMETER, TO NOZZLES, OR TO COMMUNICATING CHAMBERS; ANY WELDED JOINT CONNECTING ONE SIDE PLATE TO ANOTHER SIDE PLATE OF A PLAT-SIDED VESSEL.

CATEGORY D - WELDED JOINTS CONNECTING COMMUNICATING CHAMBERS OR NOZZLES TO MAIN SHELLS, TO TRANSITIONS IN DIAMETER, TO HEADS, OR TO PLAT-SIDED VESSELS, AND THOSE JOINTS CONNECTING NOZZLES TO COMMUNICATING CHAMBERS (FOR NOZZLES AT THE SMALL END OF A TRANSITION IN DIAMETER. SEE CATEGORY B).




WHEN $y >$ THE SMALLER OF $t/4$ OR $1/8$ ", THEN A TAPER OF A LENGTH $\geq 3y$ IS REQUIRED.

CATEGORY A OR B




TAPER MAY BE ON INSIDE OR OUTSIDE



$m \leq$ ONE-HALF THE DIFFERENCE BETWEEN THE ACTUAL SHELL AND HEAD THICKNESS
WHEN $y >$ THE SMALLER OF $t/4$ OR $1/8$ ", THEN A TAPER OF A LENGTH $\geq 3y$ IS REQUIRED.
THE SHELL PLATE g MAY BE ON EITHER SIDE OF HEAD PLATE g .

CATEGORY B



CATEGORY C

LEGEND


Δ - DENOTES DEPOSITED WELD METAL ONLY.
ALL WELDS MUST BE 100% COMPLETE PENETRATION.

t_s, t_h, t_f - NOMINAL THICKNESS OF FLAT PLATE, VESSEL SHELL OR HEAD LESS CORROSION ALLOWANCE (INCHES).




t_{min} - THE SMALLER OF $3/4$ " OR THE THICKNESS LESS CORROSION ALLOWANCE OF THE THINNER OF THE PARTS JOINED BY A FILLET, SINGLE-BEVEL, OR SINGLE-J WELD.

t_n - NOMINAL THICKNESS OF NOZZLE WALL LESS CORROSION ALLOWANCE (INCHES).


G - RADIAL GAP (INCHES).



t_1 OR $t_2 \geq 0.7 t_{min}$ OR $1/4$ " WHICHEVER IS SMALLER
 $t_1 + t_2 \geq 1/4 t_{min}$.




$\geq 0.7 t_{min}$ OR $1/4$ " WHICHEVER IS SMALLER




$\geq 0.7 t_{min}$ OR $1/4$ " WHICHEVER IS SMALLER

CATEGORY D




CATEGORY D



FOR APPLICATIONS WHERE THERE ARE NO EXTERNAL LOADS:
 $G = 1/8$ " MAX.
WITH EXTERNAL LOADS:
 $G = 0.005$ " FOR $D_o \leq 1$ "
 $G = 0.010$ " FOR $1 < D_o \leq 4$ "
 $G = 0.015$ " FOR $4 < D_o \leq 6 3/8$ "

CATEGORY D



ITEM NO.	PART NO.	DESCRIPTION OR SIZE	QTY
PARTS LIST			
UNLESS OTHERWISE SPECIFIED		ORIGINATOR	J. THEILACKER
FRACTIONS	DECIMALS	ANGLES	DRAWN
1	2	3	D. RICHARDSON
CHECKED		APPROVED	C. J. J. J.
1. BREAK ALL SHARP EDGES 1/16" MAX.		USED ON	
2. DO NOT SCALE DIMS.		MATERIAL:	
3. DIMENSIONS IN ACCORD WITH ANSI Y14.1-1975.		DATE: ALL MACHINED SURFACES	
FERMI NATIONAL ACCELERATOR LABORATORY UNITED STATES DEPARTMENT OF ENERGY			
ACCELERATOR CRYOGENIC SYSTEMS CRYOGENIC PRESSURE VESSELS TYPICAL WELDED JOINT DESIGNS			
SCALE	PLANT	DRAWING NUMBER	1650-MD-257650
NONE			

8-11-88

SUBJECT: Pressure testing
20 Dewar #2.

PRESSURIZED Low PRESS side
of vessel to 125 PSIG for
10 min

TECHNICIAN: Ken Allen

SUPERVISED: F. Walter

SAFETY: R. H. Fein

OR - R.H. Jones 11/3/89

PRESSURE VESSEL ENGINEERING NOTE
PER MANDATORY STANDARD SD37

Prepared by: J.D. Fuerst

Preparation date: 9/28/89

1 Description and Identification

Fill in the label information below:

This vessel conforms to engineering standard SD37
Vessel Title CCI Cold Compressor Cryostat #010
Vessel Number RSB416
Vessel Drawing Number CCI Dwg. 24036-E
Maximum Allowable
Working Pressure (MAWP) 85 psig + full ext. vac.
Working Temperature Range -452 °F 100 °F
Contents Helium
Designer/Manufacturer Cryogenic Consultants, Lamm's
Machine, Inc.
Test Pressure (if tested at Fermi) Acceptance
+ Full ext. vac. Date: 10-4-89
110 PSI, Hydraulic Pneumatic X
Accepted as conforming to standard by
G. Dugan
of Division/Section ACCELERATOR 11/8/89
NOTE: Any subsequent changes in contents, pressures,
temperatures, valving, etc., which affect the safety of
this vessel shall require another review and test.

Obtain from
Division/Section
Safety Officer

Actual signature
required in this
space

Reviewed by: K. Weber Date: 10/31/89

Director's signature (or designee) if the vessel is for manned areas but doesn't
conform to the requirements of the standard.

Date: _____

Lab Property Number(s): _____

Lab Location Code: _____

Purpose of Vessel(s): Reduce pressure of Tevatron satellite refrigerator
2-phase circuit

Vessel Capacity/Size: 25 liters Diameter: 12" Length: 12"

Normal Operating Pressure (OP) 5 PSIG

MAWP-OP = 80 PSIG

Is the above enough to provide relief cracking pressure tolerance plus system
uncertainty tolerance per M-9.

As an option, provide a photo of the entire vessel in the Appendix.

List the number of all pertinent drawings and the location of the originals.
(Appended copies).

Drawing #Location of OriginalCCI 24036-ECryogenic Consultants, Inc.CCI 24091-EAllentown, PACCI 24002-ECCI 24118-~~W~~D2 Design Verification

Does the vessel(s) have a U stamp? Yes X No _____. If "Yes", fill out data below and skip page 3; if "No", fill out page 3 and skip this page.


Staple photo of U stamp plate below.

Copy "U" label details to the side if photo is not clear or if copies are unreadable.


Copy data here:

Natn'l. Bd. #010
certified by Lamm's
Machine, Inc.
Allentown, PA 18103
85 psi at 100°F (Max.
allowable working press.)
with full external VAC.
-452°F at 85 psi
(Min. Design Metal
Temperature)
with full external VAC.
Mfgr's serial no. 010
year built 1989

DUPLICATE



On the sketch below, circle all applicable sections of the ASME code per Section VIII, Division I. List the results of all calculations. (Insert copies of calculations in the appendix).



Summary of ASME Code

Item	Reference ASME Code Section	CALCULATION RESULT (Required thickness or stress level vs. actual thickness or calculated stress level)
		vs.
		vs.
		vs.
		vs.
		vs.

If this vessel is exceptional or had exceptional parts, list their details under 5.6. Yes ☐ No ☒

3. **System Venting.** Provide the system schematic in the Appendix, if the vessel safety is system sensitive.

Is it possible to isolate the relief valves by a valve from the vessel? **NO** JDF 11/8/89

Yes _____ No X

If "Yes;;, the system must conform to M-5. Provide an explanation of the appended schematic. (An isolatable vessel, not conforming to M-5 violates the Standard.)

Is the relief cracking pressure set at or below the M.A.W.P.?

Yes X No _____ Actual setting 85 PSI
(A no response violates the Standard.)

Is the pressure drop of the relief system at maximum anticipated flow such that vessel pressure never rises above the following? (UG 125)

Yes X No _____
110% of MAWP (one relief)
116% of MAWP (multiple reliefs)
121% of MAWP (unexpected heat source)

Provide test or calculational proof in the Appendix.
(Non-conforming pressure rises violate the Standard.)

List of reliefs and settings:

<u>Manufacturer</u>	<u>Relief</u>	<u>Setting</u>	<u>Flow Rate</u>	<u>Size</u>
<u>Mercer Valve</u>	<u>8112541107RI</u>	<u>85 psig</u>	<u>335 SCFM air</u>	<u>1" NPT</u>
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Is the relief device an ASME stamped device? Yes X No _____

4 Operating Procedure

Is an operating procedure necessary for the safe operation of this vessel?

Yes _____ No X. If "Yes", please append.

5. Welding Information


Has the vessel been fabricated in a Fermilab shop? Yes _____ No X

If "Yes", append a copy of the welding shop statement of welder qualification and a copy of the Welding Procedure Specification (WPS) used to weld this vessel.

6 Exceptional, Existing, Used, and Non-Manned Area Vessels

Is this vessel or any part thereof in the above categories? Yes _____ No X

If "Yes", follow the Engineering Note requirements for documentation in free form below.

CCI Cold Compressor Schematic



SATELLITE REFRIGERATOR WITH COLD COMPRESSOR AND 2-PHASE RETURN DEWAR

325 PSIG
High Pressure Header

Low Pressure Header
10 PSIG

Heat Exchanger Train

DE

Cold Compressor

2-Phase Return Dewar

WE

JT

LH

Subcoolers

UC

UH

Upstream Magnet String

Downstream Magnet String

DC

DH

Total Heat Load 560W static + 240W AC



Fermilab

EXHIBIT B

Pressure Testing Permit*

Date: 9/27/89

Type of Test: ☐ Hydrostatic ☒ Pneumatic
 Test Pressure: 110 psig + full ext. vac. Maximum Allowable Working Pressure: 85 psig + full ext vac
 Items to be Tested: CCI Cold Compressor # 010

Location of Test: AZ Frig bldg. Date and Time: Week of Oct 2
 Hazards Involved: High press.

Safety Precautions Taken: Personnel removed from bldg. during test, appropriate reliefs on test equip.

Special Conditions or Requirements: Contact Accelerator Safety for final inspection & witness

Test Coordinator: J.D. Fuerst Dept/Date: AD/cryo 9/27/89
 Division/Section Safety Officer: W. Fawcett Dept/Date: 9/27/89
 Division/Section Head: W. Fawcett Dept/Date: 9/27/89
 Results: Completed OK

Witness: Richard H. Lewis Dept/Date: AD/safety 10-4-89
 (Safety Officer or Designee)

*Must be signed by division/section safety officer and division head prior to conducting test. It is the responsibility of the test coordinator to obtain signatures.

Appendix
16-OCT-89

Outline of Code Calculations

- 1.) INNER VESSEL - vessel is ASME code stamped
- 2.) VACUUM VESSEL
- 3.) RELIEF VALVE SIZING
 - A.) Vacuum Vessel
 - B.) Inner Vessel
 - i) failure modes
 - ii) relief capacities
- 4.) SUMMARY OF CALCULATIONS

1.) INNER VESSEL

This vessel was constructed by Cryogenic Consultants, Inc. and certified by Lamm's Machine, Inc. for MAWP of 85 psig plus full external vacuum (see photo of "U" label).

2.) VACUUM VESSEL

The vacuum vessel was constructed from carbon steel of unknown grade by Cryogenic Consultants, Inc. (CCI). It consists of a 20" SCH 10 pipe with a 1/2" thick bottom plate and a 1/2" thick top plate with penetrations. The ASME code stress value for grade A carbon steel (the weakest grade) is 10200 psi for welded pipe and 10400 psi for plate. The allowable stress value used in these calculations will be 80% of 10200 psi = 8160 psi.

A.) External Pressure

- i) Shell (UG-28C): a 41 1/2" long piece of 20" SCH 10S (20" o.d., 0.188" wall). $D_o/t = 20/0.188 = 106 (> 10)$; $L/D_o = 41.5/20 = 2.1$. Factor "A" from fig. 5-UGO-28.0 = 0.00065, giving a factor "B" from fig. 5-UCS-28.1 up to 300F of 9500 psi.

$$\text{Then } P_{\max} = 4B/(3D_o/t) = \underline{\underline{119 \text{ psi}}}$$

- ii) Bottom Plate (UG-34): a 20" dia, 1/2" thick flat plate.

d = head diameter = 20"

C = head attachment factor = 0.33

P = pressure, psi

S = (10200)(.80) = 8160 psi

E = weld efficiency = 0.6

$$t_{\text{req}} = d(CP/SE)^{1/2}, \text{ or } P = (SE/C)(t/d)^2$$

with $t = 1/2"$, $P = 9.3$ psi This is greater than the minimum 7 psi differential required by Fermilab Engineering Standard SD-41 (vacuum pressure vessel safety standard).

- iii) Top Plate (UG-34): a 20" dia, 1/2" thick flat plate with penetrations. Penetrations will be handled in (iv) per UG-39. As above, $P = 9.3$ psi.

- iv) Top Plate Reinforcement (UG-39):

with $P_{diff} = 7.5$ psi per SD-41, required plate thickness (flat, solid plate) $= 0.327"$ (UG-34 analysis). The cross-sectional area available for reinforcement (using the worst case [largest] hole of 8.5" dia, see CCI dwg. #24036-E) may be found like this:

$$A_{avail.reinf.} = d_{hole}(t_{act} - t_{req}) = 8.5(0.5 - 0.327) = \underline{1.47 \text{ in}^2}.$$

The required cross-sectional area $= 0.5dt$, where d = largest hole diameter $= 8.5"$ and $t = 0.327"$. This quantity $= \underline{1.39 \text{ in}^2}$.

$$A_{actual} > A_{req'd} \text{ therefore } \underline{\text{No Extra Reinforcement Req'd.}}$$

3.) RELIEF VALVE SIZING

A.) Vacuum Vessel

CGA 341 specifies a minimum 0.00024 in^2 discharge area per pound water capacity of the liquid container. The total "inner vessel" volume of this device is something less than $2000 \text{ in}^3 = 72.2 \text{ lb water}$.

relief area req'd. $= (0.000241)(72.2) = 0.0174 \text{ in}^2 = \underline{0.15" \text{ dia relief port}}$. The can is relieved by a 2" parallel plate vacuum relief so there is no problem.

B.) Inner Vessel: MAWP = 85 psi plus full external vacuum

Failure Modes-

- i) loss of vacuum-vacuum filled with 1 atm GHe (vacuum relief point):
 $Q_a = [(130-t)/4(1200-t)]G_iUA$
- ii) loss of vacuum, condensative heat transfer by air - NBS Monograph 111 chart 6.3.
- iii) fire condition: $Q_a = G_iUA^{0.82}$ from CGA S-1.3

Definitions of quantities:

- Q_a = flow capacity required, SCFM air
- G_i = 52.5 for He relieving at or below 200 psi (CGA-S-1.3)
- A = outside surface area of vessel = 7 sq ft
- U = total thermal conductance of insulating material (Btu/hr ft²F) when saturated with gaseous lading or air at 1 atm, whichever is greater
- t = temperature (°F) of gas at pressure and flowing conditions

Case i):

$U = K/L$ where K = avg. thermal conductivity of He (0-300K) = 1.55 mW/cmK and L = thickness of superinsulation = 1" (~ 100 layers quoted by CCI). Therefore, $U = (1.55\text{mW/cmK})/(2.54\text{cm}) = 0.6102\text{ mW/cm}^2\text{K}$, which = 1.075 Btu/hr ft²F. With $t = -450^\circ\text{F}$, Q_a is then equal to:

$$[(130 + 450)/4(1200 + 450)](52.5)(1.075)(10) =$$

49.6 SCFM air required.


Case ii):

For this case, a value of 110% of the absolute relieving pressure = 1.1(85 + 15) = 110 psia is used as the relieving pressure (single relief). Using figure 6A-2 from NBS monograph 111 (reproduced below), the following values of L' and T are determined for worst case Q_a :

$$L' = 12 \text{ Btu/lb efflux, } T = 12^{\circ}\text{R}$$


From fig. 6.3 of NBS mono 111 (also reproduced below), a heat flux of 5000 Btu/hr is determined for air condensation with 1" of superinsulation on 7 sq. ft. of surface area.

The required gas flow in lb/hr is found by dividing the heat flux by L' , giving 417 lb/hr flow. Required relief valve flow capacity is found using NBS mono 111 equation 6A-1:



6A-2

6.3



$$Q_a = [(13.1WC_a)/(60C)] [(ZTM_a)/(MZ_a T_a)]^{1/2} \text{ where:}$$

Q_a = req'd valve capacity, SCFM air
 W = lb/hr req'd gas flow
 C_a = gas constant = 356 for air
 C = gas constant of the gas = 378
 Z_a = compressibility factor = 1.0 for air at STP
 Z = compressibility factor for the gas at flow conditions = 0.88
 M_a = molecular weight of air = 28.97
 M = molecular weight of the gas = 4.0

$$\begin{aligned}
 T_a &= \text{temperature of air at STP} = 520^{\circ}\text{R} \\
 T &= \text{temperature of the gas at flow conditions} = 12^{\circ}\text{R} \\
 Q_a &= \frac{(13.1)(417)(356)}{60(378)} \left[\frac{0.88(12)(28.97)}{4(1)(520)} \right]^{\frac{1}{2}} \\
 &= \underline{\underline{32.9 \text{ SCFM air}}}
 \end{aligned}$$

Case iii):

Fire condition:

$$Q_a = G_i U A^{0.82} = 52.5(1.075)(7)^{0.82} = \underline{\underline{278 \text{ SCFM air}}}$$

Relief Capacities:

The inner vessel is relieved by one ASME "U" stamped 1" Mercer relief valve set for 85 psig with a stamped flow capacity of 335 SCFM air fed by a 1" stack, satisfying all relief flow requirements. The vacuum jacket is relieved by a 2" parallel plate vacuum relief. As discussed in 3(A), this size is more than adequate.

4.) SUMMARY OF CALCULATIONS

Inner Vessel:

Vessel is ASME code stamped - MAWP = 85 psig plus full vacuum.

Relief capacity through the code stamped Mercer 1" 85 psig relief = 335 SCFM air at 85 psig vs. a maximum required relief capacity of 278 SCFM air under fire conditions.

Vacuum Vessel:


Max. external pressure (per SD-37) = 9.3 psi vs. 14.5 psi actual maximum. According to Fermi Std. SD-41, vacuum vessels must withstand

collapsing pressure of 30 psid (15 psid with a safety factor of two). Since the ASME pressure vessel code has a built-in safety factor of four, any vacuum vessel designed according to ASME code may use 7 psid as minimum criterion to satisfy the safety factor of two in SD-41. This was the procedure for this vacuum shell: 9.3 psi > 7 psi.

The max. internal pressure is also 9.3 psi and is satisfactory since the vacuum vessel is properly relieved (relief sized large enough and set low enough).

Relief capacity = a 2" parallel plate vacuum relief vs. a required 0.15" dia. hole as specified by CGA 341.





PROPRIETARY AND CONFIDENTIAL
EXCEPT AS OTHERWISE AGREED IN WRIT-
ING, THE INFORMATION AND DESIGN DIS-
CLOSED HEREIN ARE THE PROPERTY OF
CRYOGENIC CONSULTANTS, INC. AND
MUST NOT BE COPIED OR DISTRIBUTED
OUTSIDE C.C.I. WITHOUT AUTHORIZED
PERSONS WITH A BETTER REASON TO KNOW
WHO BY THE USE HEREOF KNOWLEDGE
C.C.I. OWNERSHIP AND ABLE TO MAINTAIN
THIS INFORMATION AND DESIGN IN
STRICT CONFIDENCE.



22	HEX NUT, #8-32 UNC	ZN. PLTD.
21	LOCKWASHER, #8 SIZE	ZN. PLTD.
20	RD. HD. MACH. SCREW, #8-32 UNC x 1/2 LG.	ZN. PLTD.
19	CONDUIT NIPPLE, 1/2" SIZE, RIGID #424-104	7/8" NUT
18	FLAT WASHER, #10 NOM.	ST. STL.
17	HEX. HD. CAP SCREW, #10-32 UNF x 1/2 LG.	ST. STL.
16	FLAT WASHER, 1/2" NOM.	ST. STL.
15	HEX. HD. CAP SCREW, 1/2" x 20 UNF x 1/2 LG.	ST. STL.
14	ANGLE, 1 1/2" x 1 1/2" x 7' LG.	A-36
13	UNION ELBOW, SWAGelok #SS-400-9	
12	FEMALE CONNECTOR, SWAGelok #SS-400-7-A	
11	TUBE, 1/2" O.D. x .035" WL.	A-285, TH-304
10	THERMOSTAT, GRAINGER #2F399	
9	SWAGelok, HELICOID #S-2	
8	PRESSURE GAUGES, HELICOID TYPE 310	
7	MOTOR SPEED CONTROLLER FINCOR #2402150	
6	WITH SIGNAL FOLLOWER #10-19	
5	CONTROL BOX	DWG. NR. 24027-D
4	CONTROL PANEL	DWG. NR. 24103-D
3	COVER	DWG. NR. 24020-D
2	WARM END	DWG. NR. 24002-E
1	COLD END	DWG. NR. 24071-E
1	VACUUM BOX	DWG. NR. 24100-E


ITEM	DESCRIPTION
BILL OF MATERIAL	
DEC. #	ANG. #
TOLERANCE	MAX. MIN.
0.20"	20" - 80"
1/16" (0.0625")	1/16" (0.0625")
1/32" (0.03125")	1/32" (0.03125")
1/64" (0.015625")	1/64" (0.015625")
1/128" (0.0078125")	1/128" (0.0078125")
1/256" (0.00390625")	1/256" (0.00390625")
1/512" (0.001953125")	1/512" (0.001953125")
1/1024" (0.0009765625")	1/1024" (0.0009765625")
1/2048" (0.00048828125")	1/2048" (0.00048828125")
1/4096" (0.000244140625")	1/4096" (0.000244140625")
1/8192" (0.0001220703125")	1/8192" (0.0001220703125")
1/16384" (0.00006103515625")	1/16384" (0.00006103515625")
1/32768" (0.000030517578125")	1/32768" (0.000030517578125")
1/65536" (0.0000152587890625")	1/65536" (0.0000152587890625")
1/131072" (0.00000762939453125")	1/131072" (0.00000762939453125")
1/262144" (0.000003814697265625")	1/262144" (0.000003814697265625")
1/524288" (0.0000019073486328125")	1/524288" (0.0000019073486328125")
1/1048576" (0.00000095367431640625")	1/1048576" (0.00000095367431640625")
1/2097152" (0.000000476837158203125")	1/2097152" (0.000000476837158203125")
1/4194304" (0.0000002384185791015625")	1/4194304" (0.0000002384185791015625")
1/8388608" (0.00000011920928955078125")	1/8388608" (0.00000011920928955078125")
1/16777216" (0.000000059604644775390625")	1/16777216" (0.000000059604644775390625")
1/33554432" (0.0000000298023223876953125")	1/33554432" (0.0000000298023223876953125")
1/67108864" (0.00000001490116119384765625")	1/67108864" (0.00000001490116119384765625")
1/134217728" (0.000000007450580596923828125")	1/134217728" (0.000000007450580596923828125")
1/268435456" (0.0000000037252902984619140625")	1/268435456" (0.0000000037252902984619140625")
1/536870912" (0.00000000186264514923095703125")	1/536870912" (0.00000000186264514923095703125")
1/1073741824" (0.000000000931322574615478515625")	1/1073741824" (0.000000000931322574615478515625")
1/2147483648" (0.0000000004656612873077392578125")	1/2147483648" (0.0000000004656612873077392578125")
1/4294967296" (0.00000000023283064365386962890625")	1/4294967296" (0.00000000023283064365386962890625")
1/8589934592" (0.000000000116415321826934814453125")	1/8589934592" (0.000000000116415321826934814453125")
1/17179869184" (0.0000000000582076609134674072265625")	1/17179869184" (0.0000000000582076609134674072265625")
1/34359738368" (0.00000000002910383045673370361328125")	1/34359738368" (0.00000000002910383045673370361328125")
1/68719476736" (0.000000000014551915228366851806640625")	1/68719476736" (0.000000000014551915228366851806640625")
1/137438953472" (0.0000000000072759576141834259033203125")	1/137438953472" (0.0000000000072759576141834259033203125")
1/274877906944" (0.00000000000363797880709171295166015625")	1/274877906944" (0.00000000000363797880709171295166015625")
1/549755813888" (0.000000000001818989403545856475830078125")	1/549755813888" (0.000000000001818989403545856475830078125")
1/1099511627776" (0.0000000000009094947017729282379150390625")	1/1099511627776" (0.0000000000009094947017729282379150390625")
1/2199023255552" (0.00000000000045474735088646411895751953125")	1/2199023255552" (0.00000000000045474735088646411895751953125")
1/4398046511104" (0.000000000000227373675443232059478759765625")	1/4398046511104" (0.000000000000227373675443232059478759765625")
1/8796093022208" (0.0000000000001136868377216160297393798828125")	1/8796093022208" (0.0000000000001136868377216160297393798828125")
1/17592186044416" (0.00000000000005684341886080801486968994140625")	1/17592186044416" (0.00000000000005684341886080801486968994140625")
1/35184372088832" (0.000000000000028421709430404007434844970703125")	1/35184372088832" (0.000000000000028421709430404007434844970703125")
1/70368744177664" (0.0000000000000142108547152020037174224853515625")	1/70368744177664" (0.0000000000000142108547152020037174224853515625")
1/140737488355328" (0.00000000000000710542735760100185871124267578125")	1/140737488355328" (0.00000000000000710542735760100185871124267578125")
1/281474976710656" (0.000000000000003552713678800500929355621337890625")	1/281474976710656" (0.000000000000003552713678800500929355621337890625")
1/562949953421312" (0.0000000000000017763568394002504646778106689453125")	1/562949953421312" (0.0000000000000017763568394002504646778106689453125")
1/1125899906842624" (0.00000000000000088817841970012523233890533447265625")	1/1125899906842624" (0.00000000000000088817841970012523233890533447265625")
1/2251799813685248" (0.000000000000000444089209850062616169452667236328125")	1/2251799813685248" (0.000000000000000444089209850062616169452667236328125")
1/4503599627370496" (0.0000000000000002220446049250313080847263336181640625")	1/4503599627370496" (0.0000000000000002220446049250313080847263336181640625")
1/9007199254740992" (0.00000000000000011102230246251565404236316680908203125")	1/9007199254740992" (0.00000000000000011102230246251565404236316680908203125")
1/18014398509481984" (0.00000000000000005551115123125782702118158334041015625")	1/18014398509481984" (0.00000000000000005551115123125782702118158334041015625")
1/36028797018963968" (0.000000000000000027755575615628913510590791670205078125")	1/36028797018963968" (0.000000000000000027755575615628913510590791670205078125")
1/72057594037927936" (0.0000000000000000138777878078144567552953958351025390625")	1/72057594037927936" (0.0000000000000000138777878078144567552953958351025390625")
1/144115188075855872" (0.00000000000000000693889390390722837764769791755126953125")	1/144115188075855872" (0.00000000000000000693889390390722837764769791755126953125")
1/288230376151711744" (0.0000000000000000034694469519536141888238489587756328125")	1/288230376151711744" (0.0000000000000000034694469519536141888238489587756328125")
1/576460752303423488" (0.00000000000000000173472347597680709441192447938781640625")	1/576460752303423488" (0.00000000000000000173472347597680709441192447938781640625")
1/1152921504606846976" (0.000000000000000000867361737988403547205962239693908203125")	1/1152921504606846976" (0.000000000000000000867361737988403547205962239693908203125")
1/2305843009213693952" (0.0000000000000000004336808689942017736029811193469541015625")	1/2305843009213693952" (0.0000000000000000004336808689942017736029811193469541015625")
1/4611686018427387904" (0.00000000000000000021684043449710088680149055967347705078125")	1/4611686018427387904" (0.00000000000000000021684043449710088680149055967347705078125")
1/9223372036854775808" (0.000000000000000000108420217248550443400745279836738525390625")	1/9223372036854775808" (0.000000000000000000108420217248550443400745279836738525390625")
1/18446744073709551616" (0.000000000000000000054210108624275221700372639918369261953125")	1/18446744073709551616" (0.000000000000000000054210108624275221700372639918369261953125")
1/36893488147419103232" (0.0000000000000000000271050543121376108501863199591846309765625")	1/36893488147419103232" (0.0000000000000000000271050543121376108501863199591846309765625")
1/73786976294838206464" (0.00000000000000000001355252715606880542509315997959231548828125")	1/73786976294838206464" (0.00000000000000000001355252715606880542509315997959231548828125")
1/147573952589676412928" (0.000000000000000000006776263578034402712546579989796157744140625")	1/147573952589676412928" (0.000000000000000000006776263578034402712546579989796157744140625")
1/295147905179352825856" (0.0000000000000000000033881317890172013562732899948980788720703125")	1/295147905179352825856" (0.0000000000000000000033881317890172013562732899948980788720703125")
1/590295810358705651712" (0.00000000000000000000169406589450860067813664499744903943603515625")	1/590295810358705651712" (0.00000000000000000000169406589450860067813664499744903943603515625")
1/1180591620717411303424" (0.000000000000000000000847032947254300339068322499872470218017578125")	1/1180591620717411303424" (0.000000000000000000000847032947254300339068322499872470218017578125")
1/2361183241434822606848" (0.0000000000000000000004235164736271501695341612499362351090087890625")	1/2361183241434822606848" (0.0000000000000000000004235164736271501695341612499362351090087890625")
1/4722366482869645213696" (0.00000000000000000000021175823681357508476708062496811755450439453125")	1/4722366482869645213696" (0.00000000000000000000021175823681357508476708062496811755450439453125")
1/9444732965739290427392" (0.000000000000000000000105879118406787542383540312484058772252197265625")	1/9444732965739290427392" (0.000000000000000000000105879118406787542383540312484058772252197265625")
1/18889465931478580854784" (0.0000000000000000000000529395592033937711917701562420293861260986328125")	1/18889465931478580854784" (0.0000000000000000000000529395592033937711917701562420293861260986328125")
1/37778931862957161709568" (0.00000000000000000000002646977960169688559588507812101469306304931640625")	1/37778931862957161709568" (0.00000000000000000000002646977960169688559588507812101469306304931640625")
1/75557863725914323419136" (0.00000000000000000000001323488980084844279794253906050734653152469230625")	1/75557863725914323419136" (0.00000000000000000000001323488980084844279794253906050734653152469230625")
1/151115727451828646838272" (0.000000000000000000000006617444900424221398971269530253673265762346153125")	1/151115727451828646838272" (0.000000000000000000000006617444900424221398971269530253673265762346153125")
1/302231454903657293676544" (0.000000000000000000000003308722450212110699485634765126836632861173078125")	1/302231454903657293676544" (0.000000000000000000000003308722450212110699485634765126836632861173078125")
1/604462909807314587353088" (0.000000000000000000000001654361225106055349742817382563418316405865390625")	1/604462909807314587353088" (0.000000000000000000000001654361225106055349742817382563418316405865390625")
1/1208925819614629174706176" (0.0000000000000000000000008271806125530276748714136912817071815229326953125")	1/1208925819614629174706176" (0.0000000000000000000000008271806125530276748714136912817071815229326953125")
1/2417851639229258349412352" (0.0000000000000000000000004135903062765138374357068456408535907614673078125")	1/2417851639229258349412352" (0.0000000000000000000000004135903062765138374357068456408535907614673078125")
1/4835703278458516698824704" (0.00000000000000000000000020679515313825691871785342282042679538073365390625")	

PROPRIETARY AND CONFIDENTIAL
 EXCEPT AS OTHERWISE INDICATED IN THIS DOCUMENT, THE INFORMATION AND DESIGN ARE THE PROPERTY OF THE CONSULTANT, INC. AND SHALL NOT BE COPIED OR REPRODUCED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF THE CONSULTANT, INC. THE INFORMATION AND DESIGN ARE THE PROPERTY OF THE CONSULTANT, INC. AND SHALL NOT BE COPIED OR REPRODUCED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF THE CONSULTANT, INC.




ITEM	DESCRIPTION	QUANTITY
1	BASE PLATE	1
2	SHAFT	1
3	CONNECTING ROD	1
4	CRANK BLOCK	1
5	CRANK SUB-ASSEMBLY	1
6	FLYWHEEL	1
7	CRANK SUB-ASSEMBLY	1
8	SPACER	1
9	CLAVIS SUB-ASSEMBLY	1
10	MOTOR	1
11	PULLEY	1
12	WHEEL	1
13	BEARING	2
14	BEARING	2
15	RETAINING RING	2
16	RETAINING RING	2
17	RETAINING RING	2
18	RETAINING RING	2
19	RETAINING RING	2
20	RETAINING RING	2
21	RETAINING RING	2
22	RETAINING RING	2
23	RETAINING RING	2
24	RETAINING RING	2
25	RETAINING RING	2
26	RETAINING RING	2
27	RETAINING RING	2
28	RETAINING RING	2
29	RETAINING RING	2
30	RETAINING RING	2
31	RETAINING RING	2
32	RETAINING RING	2
33	RETAINING RING	2
34	RETAINING RING	2
35	RETAINING RING	2
36	RETAINING RING	2
37	RETAINING RING	2
38	RETAINING RING	2


BILL OF MATERIAL
 DATE: 10/1/80
 DRAWN BY: [Name]
 CHECKED BY: [Name]
 APPROVED BY: [Name]
 PROJECT: [Project Name]
 SHEET: [Sheet Number]
 TOTAL SHEETS: [Total Sheets]
 SCALE: [Scale]
 UNIT: [Unit]
 MATERIAL: [Material]
 QUANTITY: [Quantity]
 PRICE: [Price]
 TOTAL: [Total]
 COMMENTS: [Comments]
 SIGNATURE: [Signature]
 TITLE: [Title]
 DATE: [Date]
 PROJECT: [Project Name]
 SHEET: [Sheet Number]
 TOTAL SHEETS: [Total Sheets]
 SCALE: [Scale]
 UNIT: [Unit]
 MATERIAL: [Material]
 QUANTITY: [Quantity]
 PRICE: [Price]
 TOTAL: [Total]
 COMMENTS: [Comments]
 SIGNATURE: [Signature]
 TITLE: [Title]
 DATE: [Date]



SECTION A-A



PLAN VIEW



VIEW B-B

NOTES:
1. LOWER ITEM-14 INTO CAVITY USING POSITIONING TOOL
DNG. NR. 24130-B

PROPRIETARY AND CONFIDENTIAL
EXCEPT AS OTHERWISE NOTED IN THIS
DNG, THE INFORMATION AND DESIGN OR
CLOSED HEREIN ARE THE PROPERTY OF
CRYOGENIC CONSULTANTS, INC. AND
SHALL NOT BE COPIED OR REPRODUCED
WITHOUT THE WRITTEN PERMISSION OF
CRYOGENIC CONSULTANTS, INC. IN ANY
FORM OR BY ANY MEANS, ELECTRONIC
OR MECHANICAL, INCLUDING PHOTOCOPYING,
RECORDING, OR BY ANY INFORMATION
STORAGE AND RETRIEVAL SYSTEM.

ITEM		DESCRIPTION	
1		COLD END ASSEMBLY	
2		COLD GAS PUMP	
3		COLD GAS PUMP	
4		COLD GAS PUMP	
5		COLD GAS PUMP	
6		COLD GAS PUMP	
7		COLD GAS PUMP	
8		COLD GAS PUMP	
9		COLD GAS PUMP	
10		COLD GAS PUMP	
11		COLD GAS PUMP	
12		COLD GAS PUMP	
13		COLD GAS PUMP	
14		COLD GAS PUMP	
15		COLD GAS PUMP	
16		COLD GAS PUMP	
17		COLD GAS PUMP	
18		COLD GAS PUMP	
19		COLD GAS PUMP	
20		COLD GAS PUMP	
21		COLD GAS PUMP	
22		COLD GAS PUMP	
23		COLD GAS PUMP	
24		COLD GAS PUMP	
25		COLD GAS PUMP	
26		COLD GAS PUMP	
27		COLD GAS PUMP	
28		COLD GAS PUMP	
29		COLD GAS PUMP	
30		COLD GAS PUMP	
31		COLD GAS PUMP	



OCT 3 1988

ADDENDUM

It must be impossible to isolate relief valves from their associated volumes. Also, lines connecting volumes to relief valves must not diminish relieving capacity such that capacity falls below the criteria stated on page 4 of SD-37. With this in mind, the following calculations show the adequacy of the relief system on CCI cold compressors #010 and #011.

Given the geometry of the compressor, the flow path leading to the 1" 85 psig Mercer relief valve from the intake surge volume passes through both the intake and exhaust check valves. If the piston were ever to come to rest on the bottom of the cylinder (through improper dead volume adjustment or disconnection of the crank arm, for example), one might expect the piston to hold the intake valve shut. This would both obstruct the flow path through the compressor and isolate the relief valve from the intake side of the machine.

This scenario is prevented through installation of thin spacers tack welded to the top of the piston. These spacers ensure that the piston can never come to rest at the cylinder bottom and hold the intake valve closed. Spacer thickness was determined by ensuring that when the piston/cylinder head clearance is equal to spacer thickness, the intake valve can open enough to supply the same amount of flow area as that supplied by the 1" line leading to the 1" Mercer relief valve. This required spacer height is 0.141". A spacer thickness of 5/32" has been chosen. The sketches below outline the details of the calculation of required intake valve travel (spacer thickness).



$$\text{Flow area of 1" hole} = 0.785 \text{ in}^2$$

$$\text{Flow area} = \pi (2.5') (x'') = 0.785 \text{ in}^2$$

$$\text{where } x = h/\sqrt{2}$$

$$\text{so } h = \frac{\sqrt{2} (0.785 \text{ in}^2)}{\pi (2.5 \text{ in})} = 0.141''$$

$$\therefore \text{spacer height} = \underline{\underline{5/32''}} = 0.156''$$